



ST. MARY'S COUNTY
HEALTH DEPARTMENT

Meenakshi G. Brewster, MD, MPH - Health Officer

Administration, Records & Health Services: 301 - 475 - 4330

Environmental Health: 301 - 475 - 4321

Medical Assistance Transportation: 301 - 475 - 4296

Maryland Relay Service: 1 - 800 - 735 - 2258

Email: smchd.healthdept@maryland.gov

LUGM#: **SFDD22-1364**

Transmittal Form

Owner/Applicant: Suzanne Borenzweig

Surveyor: Linear

Property Location: 48635 Whitaker Road

Tax Map: 67 Grid: 16 Parcel: 194

Section: Lot: 9 District: 1

Subdivision: Della Bourne

Property ID: 1015699

SMCHD File #: 1241-88

Date Received: 09-20-22 Number of Copies: 1

OK for Sign- OK for Record Set- OK for Perc Preservation- No Objection

Needs Revisions- See Comments

Reviews/Sign By: [Signature] 10/12/2022

Date: 10-4-22



ST. MARY'S COUNTY HEALTH DEPARTMENT

Meenakshi G. Brewster, MD, MPH - Health Officer

Administration, Records & Health Services: 301 - 475 - 4330

Environmental Health: 301 - 475 - 4321

Medical Assistance Transportation: 301 - 475 - 4296

Maryland Relay Service: 1 - 800 - 735 - 2258

Email: smchd.healthdept@maryland.gov

Property ID: 1015499

Property Address: 48635 Whitaker Rd.

Building Permit Site Plan w/ proposed or existing SRA Checklist

General Notes

☒ 1. Property ID Block (Tax Map, Block, and Parcel)

☒ 2. Septic system sized for 400 GPD

N/A Health Dept. SRA Note

☒ 4. Comprehensive Water and Sewer Plan (expanded note req'd with waiver requirement)

☒ 5. "Well or Septic within 100 feet"

☒ 6. Type of water supply

☒ 7. Water/Sewer Categories Listed

Req BAT O&M Note

N/A 9. Dug well/Privy proposed, construction notes

N/A 10. Dug well/Privy proposed, Amish/Mennonite note

Septic System

☒ 1. Pump Pit Shown (if required) & labeled

☒ 2. Tank 10 ft from structures and labeled

Req: ☒ 3. Tank/BAT must be tar coated

☒ 4. Drainfield parallel to contours & equal in length

☒ 5. Drainfield length correct

☒ 6. Drainfields 10 ft apart

☒ 7. Replacement systems shown

☒ 8. Force main needs to be sleeved

☒ 9. >10 ft from pools and property lines

☒ 10. Septic tank or BAT sized for 400 GPD

Sewage Reserve Area

☐ 1. SRA designated N/A

☐ 2. SRA matches record plat

☐ 3. SRA correct size (1+1 or 10,000 sf)

☐ 4. Perc holes identified and correctly labeled

☐ 5. Topography (2' contours)

- ☐ 6. >25 ft from slopes >25% slopes (when 25% slope is downgrade of SRA)
- ☐ 7. > 100 ft from streams, tidal waters, ponds
- ☐ 8. >25 ft from drainage easements, swales, non-tidal wetlands
- ☐ 9. >25 ft from drywells, all SWM
- ☐ 10. >50 ft from drilled wells
- ☐ 11. >100 ft from shallow wells
- ☐ 12. >10 ft from proposed house site and property lines
- ☐ 13. > 10 ft from pools
- ☐ 14. >15 ft from Right of Ways
- ☐ 15. Show _____ linear ft of trench
- ☐ 16. Revise easement as indicated

Well Site

- ☒ 1. > 50 ft from all SRA/septics (drilled well)
- ☒ 2. >100 ft from all SRA/septics (shallow well)
- ☒ 3. 10 ft from property lines
- ☒ 4. >20 ft from house site
- ☒ 5. > 15 ft from right of ways
- ☒ 6. Well site accessibility
- ☒ 7. Water line/connection to structure
- ☒ 8. Existing well sites (abandonment letter required)
- ☒ 9. GAP required (10-24 lots)
- ☒ 10. Well variance required

Other Requirements

- ☒ 1. North Arrow
- ☒ 2. House/structure location
- ☒ 3. Driveways/Right of Ways labeled
- ☒ 4. Health Dept Approval Block
- ☒ 5. Vicinity Map
- ☒ 6. Scale
- ☒ 7. Surveyor's Stamp and Signature (check that license is valid)
- ☒ 8. Waiver request required

Mound System

In house design.

- ☒ 1. Mound Orientation Correct
- ☐ 2. Design Flow (GPD)
- ☐ 3. Infiltration Rate
- ☐ 4. General Note referencing mound design to engineered mound plans (include date on plans and engineer name)
- ☐ 5. Pump pit is sealed coat to be watertight by manufacturer
- ☐ 6. Disturbance Note
- ☐ 7. Note about soils not being wet
- ☒ 8. 25 foot no compaction zones shown
- ☐ 9. Observation ports shown
- ☐ 10. Effluent filter required
- ☐ 11. Turn ups shown
- ☐ 12. System Profile (w/ risers coming to ground surface)
- ☒ 13. Design Packet and Site Plan Match

Comments: ① Please add to General Notes: BAT O+M Note:
"The property owner shall maintain and operate all
new and existing BAT Systems for the life of the system."

~~② Show position section of water line that
runs under driveway. EXISTING~~

③ Show BAT/pump pit is ~~sealed~~ sealed and
water tight by manufacture.

LEHS/Date

Alanna Meddaugh 10.6.22