24-0666

- BFE 5' FPE 8'
- Need new floor plan illustrating the home being raised.
  - If on a crawl space flood vents will be needed.
  - If raising it higher & putting an enclosure, a non-conversion will be needed. only parking storage or access to above.
- Need the agreement to submit Elevation certs signed
- Pool equipment will need to be elevated to FPE

* foundation plan w/ struct. separation
* elev. of pool equip + utility equip - above bfe
* complete EC

7u.6.2.C

* crawl w/ vents

* NCA for pool in? 7u-18 (4) NO

* flordia Regs for these rooms w/ pools